


TYPICAL THERMAENTRY MODULE CONNECTION DIAGRAM

BEARING THERMISTORS

1. THERE ARE QTY. 1 OR 2 BEARING THERMISTORS (QTY. 1 FOR LOWER/DE (DRIVE END) & QTY. 1 FOR UPPER/ODE (OPPOSITE DRIVE END) INSTALLED ON MOTOR. THESE THERMISTORS ARE WIRED TO A MOTOR MOUNTED OR REMOTE MOUNTED THERMAENTRY CONTROL MODULE.
2. REFER TO CONNECTION DIAGRAM ATTACHED TO THE CONTROL MODULE FOR CORRECT WIRING OF THE THERMISTORS AND CONTROL MODULE. (ALSO SHOWN BELOW)



ACCESSORY LISTING			
QTY 1 - THERMAENTRY MODULE			
QTY 1 OR 2 - BEARING THERMISTORS			

ITEMS AND MATERIALS SPECIFIED HEREIN MUST COMPLY WITH THE EUROPEAN REDUCTION OF HAZARDOUS SUBSTANCES (RoHS 2) DIRECTIVE 2011/65/EU, REGULATIONS (EC) NO. 1907/2006 ("REACH") AS OF 1 JUNE 2007 AND ALL SUBSEQUENT UPDATES. PLEASE REFER TO THE OFFICIAL EU DOCUMENTS FOR COMPLETE DEFINITION, RESTRICTIONS, AND LIMITS FOR EACH SUBSTANCE.

REVISION DESCRIPTION FOR: MISC  
 STL1213-00 UPDATED TO NIDEC FORMAT.

SCALE NONE UNITS IN  
 TOLERANCES ON DIMENSIONS (UNLESS OTHERWISE SPECIFIED)  
 INCHES mm  
 .XX = ± .03  
 .XXX = ± .015  
 ANGLES X° = ±1°

CSTG NO. ---	PART NO. ---	FRAME ---	TYPE ---
TITLE <b>CUSTOMER CONNECTION DIAGRAM</b>		<b>NIDEC MOTOR CORPORATION</b>	
ISSUED BY R. KING	APPROVED BY J. HAGENE	REVISION DATE 20-DEC-13	
CODE	DWG NO. <b>0421115</b>	REV <b>C</b>	SHEET NUMBER 1 OF 1 DWG SIZE <b>A</b>

**NIDEC CONFIDENTIAL**  
 NIDEC MOTOR CORPORATION 20-Dec-13