

1. THERE ARE QTY-6 RESISTANCE TYPE TEMPERATURE DETECTORS (RTD) INSTALLED IN THE STATOR WINDINGS (1 PER PHASE PER WINDING.) REFER TO NAMEPLATE ATTACHED TO THE MOTOR ADJACENT TO ACCESSORY OUTLET BOX FOR RATING OF THE RTD'S.

2. DETECTORS ARE INSTALLED IN PHASES AS SHOWN.

PHASE	A	B	C
RTD *HIGH SPEED	1H	2H	3H
RTD *LOW SPEED	1L	2L	3L



ACCESSORY LISTING
QTY-6 2 LEAD RTD'S

REVISION DESCRIPTION FOR: MISC	SCALE NONE	UNITS IN	DRAWING, CONNECTION DIAGRAM	NIDEC MOTOR CORPORATION
STL0211 - UPDATED FORMAT.	TOLERANCES ON DIMENSIONS (UNLESS OTHERWISE SPECIFIED)			
MATERIAL: ---	INCHES	mm	ISSUED BY R. KING	APPROVED BY C. CADE
MUST BE COMPLIANT TO RoHS DIRECTIVE EU 2002/95/IEC AND REGULATION EC 1907/2006 (REACH) AS AMENDED	ANGLES X°= ±1°		REVISION DATE 23-FEB-11	REV A
			CODE	DWG NO. 0463458
				SHEET NUMBER 1 OF 1
				DWG SIZE A