


ALT: A 833981 A

WINDING RTD'S

1. THERE ARE QTY-3 RESISTANCE TYPE TEMPERATURE DETECTORS (RTD) INSTALLED IN THE STATOR WINDING, 1 PER PHASE. REFER TO NAMEPLATE ATTACHED TO THE MOTOR ADJACENT TO ACCESSORY OUTLET BOX FOR RATING OF THE RTD'S.

2. DETECTORS ARE INSTALLED IN PHASES AS SHOWN.

| PHASE | A | B | C |
|---------|---|---|---|
| RTD NO. | 1 | 2 | 3 |



ACCESSORY LISTING
QTY-3 3 LEAD RTD'S

| ALT CHANGE (LET NOTICE NO.) | DESCRIPTION OF CHANGE | SCALE | DATE | BY | U.S. ELECTRICAL MOTORS DIVISION OF EMERSON ELECTRIC CO. ST. LOUIS, MISSOURI | TITLE |
|-----------------------------|-----------------------|----------|----------|-----|---|-----------------------------|
| - | --- | NONE | 11-30-89 | DLH | DRWN 13-MAY-80, DLH | CUSTOMER CONNECTION DIAGRAM |
| A | MOD | 7-JUN-00 | UPDATED | FWK | RVSD 7-JUN-00, FWK | |
| | | | | REP | APPD 7-JUN-00, REP | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| ALT: | A | 833981 | A | CDG | | |