


WINDING RTD'S

1. THERE ARE QTY-3 RESISTANCE TYPE TEMPERATURE DETECTORS (RTD) INSTALLED IN THE STATOR WINDING, 1 PER PHASE. REFER TO NAMEPLATE ATTACHED TO THE MOTOR ADJACENT TO ACCESSORY OUTLET BOX FOR RATING OF THE RTD'S.
2. DETECTORS ARE INSTALLED IN PHASES AS SHOWN.

PHASE	A	B	C
RTD NO.	1	2	3



ACCESSORY LISTING
QTY-3 3 LEAD RTD'S

REVISION DESCRIPTION FOR: MISC	SCALE NONE	UNITS IN	TITLE		NIDEC MOTOR CORPORATION
STL0211 - UPDATED FORMAT.	TOLERANCES ON DIMENSIONS (UNLESS OTHERWISE SPECIFIED)		CUSTOMER CONNECTION DIAGRAM		
MATERIAL: ---	INCHES	mm	ISSUED BY R. KING	APPROVED BY C. CADE	REVISION DATE 23-FEB-11
MUST BE COMPLIANT TO RoHS DIRECTIVE EU 2002/95/IEC AND REGULATION EC 1907/2006 (REACH) AS AMENDED	ANGLES X°= ±1°		CODE	DWG NO. 0833981	REV C
					SHEET NUMBER 1 OF 1
					DWG SIZE A